

# District School Board of Pasco County

## Bid Recommendation

<b>Bid Title</b>	A/C Chemicals Maintenance Department		<b>Number of Vendors Notified</b>	317
<b>Bid Number</b>	06-133-LR		<b>Number of Bids Distributed</b>	26
<b>Date Solicited</b>	February 28, 2006		<b>Number of Vendors Bidding</b>	3
<b>Date Opened</b>	March 22, 2006		<b>Number of Formal “No Bid” Responses</b>	0
<b>Date Board Presentation</b>	May 2, 2006		<b>Funding Source</b>	Asset
<b>Total Savings</b>	<b>\$1,398.42</b>		<b>Grand Total of Bid</b>	\$30,000.00

**Recommendation:**

Recommend acceptance of bid from American Technical Services of Central Florida, as noted on attached bid tabulation sheet, as lowest and best, responsive and responsible “all-or-none” bid meeting written specifications.

**Term of Contract:**

This bid is for chemicals “as needed” by the Maintenance Department for use as a scale/corrosion inhibitor for water-treatment, cooling towers at various schools throughout the District. This is a three-year bid renewable annually based upon mutual agreement of both parties. The first contract period shall be effective from May 3, 2006 to April 4, 2007.

**Notations and Exceptions:**

Aquatech of Florida, Inc. bid price per 55-gallon drum was lower, however due to the dilution ration for solution feed it made the number of drums needed per year higher which made their annual cost higher.

Offers from the vendors listed herein are the only offers received timely as of the above opening date and time. All other offers submitted in response to this solicitation, if any, are hereby rejected as late.

**Bids Evaluated By:**

Rich Graziano, Crew Chief, Maintenance Department

**Bids Prepared By:**

Laurie Roberts, CPPB, Buyer, Purchasing Department

**Reviewed and Authorized By:**

Kendra Goodman, CPPB, Purchasing Agent

DISTRICT SCHOOL BOARD OF PASCO COUNTY BID TABULATION

DATE OF OPENING: March 22, 2006 @ 2:30 PM		American Technical Services of Central Florida	Aquasure, Inc.
BID TITLE: A/C Chemicals - Maintenance Dept.		P.O. Box 16703	6201 118th Ave N
BID # 06-133-LR		Temple Terrace, FL 33687	Largo, FL 33773
<b>**Board Meeting 5/2/06**</b>			
	DESCRIPTION	TOTAL PRICE	TOTAL PRICE
	Number of Drums Needed Per Year	17	17
	Price Per 55-Gallon Drum	\$554.30	\$567.00
	Yearly Gallon Quantity Needed	935	935
	Dilution Ratio for Solution Feed	5.3 of C-370 to 45.7 gals. of water per 55 gals. drum	5 Gal. to 55 Gal.
	Dosage Rate Required (Total Parts Per Million Applied)	2 ppm PO 3/4-	4-6 mg./L as Phosphonate

DISTRICT SCHOOL BOARD OF PASCO COUNTY BID TABULATION

DATE OF OPENING: March 22, 2006 @ 2:30 PM		Aquatech of Florida, Inc.
BID TITLE: A/C Chemicals - Maintenance Dept.		3215 A Fairfield Ave. South
BID # 06-133-LR		St. Pete, FL 33712
<b>**Board Meeting 5/2/06**</b>		
	DESCRIPTION	TOTAL PRICE
	Number of Drums Needed Per Year	21
	Price Per 55-Gallon Drum	\$505.00
	Yearly Gallon Quantity Needed	1155
	Dilution Ratio for Solution Feed	10
	Dosage Rate Required (Total Parts Per Million Applied)	100